



**UAB „ELEKTROTECHNINIŲ GAMINIŲ
SERTIFIKAVIMO CENTRAS“ (EGSC)**

Kaukysos g. 18, LT -11342 Vilnius
Lietuvos Respublika

**Atitikties
sertifikatas**

**Certificate
of Conformity**

No. LS801.B12008

**This certificate of conformity gives a right
to mark production with the mark of conformity:**



Issued to UAB „VENTMATIKA”,
Išradėjų str. 13b, LT-78149 Šiauliai, Lithuania.

This certificate of conformity indicates that product

electrical duct heater

type (model)

EKA...-...-f*

EKS...x... ..*; EKS-PG...x... ..*

*... - diameter of duct (from 100 mm to 400 mm)

*...x... - duct width and height, mm

.. - power (from 0,3 kW to 12 kW)

.. - power (from 0,3 kW to 200 kW)

. - phase (1, 2, 3)

(total 3 units)

manufactured by

UAB „VENTMATIKA”,
Išradėjų str. 13b, LT-78149 Šiauliai, Lithuania

is in conformity with the requirements of the standard (-s):

LST EN 60335-2-30:2010+AC:2010.

The certificate of conformity is issued on the basis:

EGSC test report No.AFD.01.2236-12 dated 28.09.2012 and factory inspection report dated 21.03.2012.

Expiry date: 28th September 2015

Issue date: 28th September 2012

Director

V. Keršys

